SafeBox 32
(Class II)



VIEW WITH COVERS REMOVED



Item	Description	Manufacturer	Part No.
1	3 Pole Isolating Switch (80A)	ABB	OT80F3 / 1SCA105798R1001
2	Isolating Switch Red/Yellow Handle & Shroud	ABB	OHY80S
3	FuseHolders (32A Camaster)	Bussmann	CM32F
4			
5	Stud Terminals (M10) (M300/42.FF)	ABB	1SNA 115 149 R2000
6	Terminal Partition (ECP42)	ABB	1SNA 113 692 R1700
7			
8	Through Terminals (Grey M10/10)	ABB	0115 120.17
9	Through Terminals (Grey M2.5/5)	ABB	0115 486.03
10			

NAME	DATE	PWD	26-03-12	CPS	14.01.2013	CPS	23.04.2013	CPS	30.09.2014	CPS	27.11.2014	DH	12.07.2018
ISSUE -		ISSUE - A		ISSUE - B		ISSUE - C		ISSUE - D		ISSUE - E		ISSUE - F	
DETAILS		FIRST ISSUE		DRAWING UPDATED		IDENTIFICATION LABEL MODIFIED		PARTS LIST ADDED		INCOMING LABEL ID & SECTORAL CABLE NOTE ADDED		RING POWER REFERENCES REMOVED	
CHK'D	APP'D	CHK'D	APP'D										

Henry Williams Ltd - Electrical Projects — DARLINGTON ENGLAND

CUSTOMER — ISSUE APPROVED

CONTRACT TITLE SafeBox Range — ON

PRODUCED — PLAN DATE

APPROVED — DWG. No

SafeBox 32
Class II
General Arrangement

22190-32-II

The copyright and all other rights related to this drawing or document remains at all times with Messrs. Henry Williams Electrical Ltd. Without their written authorisation it must neither be copied or reproduced nor be communicated or rendered acceptable or profitable in any form to any third parties.

ISSUE F