



SafeBox 105 (Class II)



VIEW WITH COVERS REMOVED

Item	Description	Manufacturer	Part No.
1	3 Pole Isolating Switch (80A)	ABB	OT80F3 / 1SCA105798R1001
2	Isolating Switch Red/Yellow Handle & Shroud	ABB	OHY80S
3	FuseHolders (32A Camaster)	Bussmann	CM32F
4	Surge Suppressor	PD Devices	RTM150/650
5	Stud Terminals (M10) (M300/42.FF)	ABB	1SNA 115 149 R2000
6	Terminal Partition (ECP42)	ABB	1SNA 113 692 R1700
7	Through Terminals (Grey M16/12)	ABB	0115 129.14
8	Through Terminals (Grey M10/10)	ABB	0115 120.17
9	Through Terminals (Grey M2.5/5)	ABB	0115 486.03
10			



Henry Williams Ltd - Electrical Projects		DARLINGTON ENGLAND
CUSTOMER	*****	ISSUE APPROVED
CONTRACT TITLE	SafeBox 100-Series (Class II)	ON 22190
PRODUCED		PLAN DATE
APPROVED		DWG. No
SAFEBOX 105 CLASS II General Arrangement		22190-105-II
The copyright and all other rights related to this drawing or document remains at all times with Messrs. Henry Williams Electrical Projects Ltd. Without their written authorisation it must neither be copied or reproduced nor be communicated or rendered acceptable or profitable in any form to any third parties.		ISSUE E

DH 26.09.12	CPS 06.10.14	CPS 12.02.2015	CPS 28.05.2015	DH 12.07.2018
ISSUE - A FIRST ISSUE	ISSUE - B PARTS LIST ADDED	ISSUE - C INCOMING LABEL ID & SECTORAL CABLE NOTE ADDED	ISSUE - D M16/12 TERMINAL REFERENCE ADDED	ISSUE - E RING POWER REFERENCES REMOVED